

**Section 6: Ramps, Curb-Ramps and Slopes**  
**When a slope measures more than 5%, it is a ramp.**

Ramp Location:

Questions	Yes	No	Data	Modifications/ Notes
1. Is the surface of the ramp stable, firm, and slip-resistant?				
2. Is the ramp at least 48" wide?				
3. Is there a landing at the top of the ramp that measures at least 60" wide by 60" long?				
4. Is there an intermediate landing for each 30" rise of the ramp that is at least 60" long and as wide as the ramp?				
5. Is there a 60" wide by 72" long intermediate landing wherever the ramp changes direction?				
6. Is there a landing at the bottom of the ramp that is at least 72" long and as wide as the ramp?				
7. Is the slope of the ramp 8.33% or less?				
8. Is the ramp cross-slope 2% or less?				
9. Is the top landing level with no more than 2% slope in any direction?				
10. Is the intermediate landing level with no more than 2% slope in any direction?				

Questions	Yes	No	Data	Modifications/ Notes
11. Is the bottom landing level with no more than 2% slope in any direction?				
12. Where the ramp or landing has a vertical drop-off on either side, are wheel guides or raised curbs (at least 2" high) provided?				
13. Does the ramp have continuous handrails for the full length of the ramp on both sides?  (Exception: At exterior doors when the ramp landing and the door landing overlap, a ramp does not require handrails if it is less than 6" high or 72" in length.)				
14. If required, are the handrails mounted between 34" to 38" above the ramp surface?				
15. Do the handrails extend 12" horizontally over each landing?				
16. Are the handrail edges rounded and returned to the ground, wall, or post?				
17. Do circular handrails have a 1 ¼" to 2" diameter?				
18. Do non-circular handrails have a perimeter of 4" minimum and 6 ¼" maximum and a cross section dimension of 2 ¼" maximum?				

Questions	Yes	No	Data	Modifications/ Notes
19. If the handrails are located adjacent to a wall, is the gap between the handrail and the wall at least 1 ½"?				
20. Do handrails protrude no more than 4 ½" into path of travel?				

**Modifying measures needed at this site on Election Day:**

- ☐ Temporary ramp(s) needed  
       \_\_\_\_\_ Ramp(s) needed
- ☐ Temporary wheel guides or edge protection needed  
       \_\_\_\_\_ Wheel guides or edge protection needed
- ☐ Comments

---



---

## Curb-Ramp Checklist

**When a slope provides access across a curb, it is a curb-ramp or curb-cut.**

**Curb-Ramp Location:**

Questions	Yes	No	Data	Modifications/ Notes
1. Is the surface of the curb-ramp stable, firm and slip-resistant?				
2. Is the curb-ramp at least 48" wide?				
3. Is there a top landing a minimum of 48" long?				
4. Is the bottom landing at least 48" long?				
5. Is there a 12" wide grooved border cut into the walkway surface along the top and sides of the curb-ramp?				
6. Is the maximum slope of the curb-ramp no more than 8.33%?				
7. Is the cross-slope 2% or less?				
8. Is the top landing slope 2% or less in any direction?				
9. Is the first 24" of the bottom landing slope 5% or less in all directions?				
10. If there is a drop-off next to the curb ramp, does the curb ramp have either wheel guides or side flares?				

**Modifying measures needed at this site on Election Day:**

☐ Temporary ramp(s) needed

\_\_\_\_\_ Ramp(s) needed

☐ Temporary wheel guides or edge protection needed

\_\_\_\_\_ Wheel guides or edge protection needed

☐ Comments

---

---